


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen

Visitors/ postal address:
45879 Gelsenkirchen

Switchboard 0049(0209) 9242-0
Fax (0049209) 9242-222
Internet www.hyg.de

Reference: W-270357e-16-Ho
Responsible: Dipl.-Ing. (FH) S. Horn

Test - certificate

hygiene – conformity check to the design requirements
of VDI 2047, part 2 (01/2015)

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthausener Straße 21
49879 Gelsenkirchen

Test object: Advanced Dry Cooler (ADC)

Manufacturer: JAEGGI Hybridtechnologie AG
Hirschgässlein 11
CH-4051 Basel

Basis of the examination: ✓ VDI 2047, part 2 (01/2015)

Validity period: 5 years 06/2016 – 06/2021

Test report: W-270357-16-Ho



In conclusion it can be stated that the examined Advanced Dry Cooler (ADC), as specified in the test report W-270357-16-Ho, is in compliance with the design requirements of the above mentioned regulation.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water Hygiene
and Environmental Microbiology

(Dipl.-Ing. (FH) S. Horn)
Department of Water Hygiene
and Environmental Microbiology

issued 24.06.2016, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant design requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt-ID: DE125018356
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)