


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen

Visitors/ postal address:
45879 Gelsenkirchen

Switchboard 0049(0209) 9242-0
Fax (0049209) 9242-222
Internet www.hyg.de

Reference: W-264299e-15-Ho
Responsible: Dipl.-Ing. (FH) S. Horn

Certificate

Hygiene – conformity check

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: evaporation coolers type „HTK“

Manufacturer: JAEGGI Hybridtechnologie AG
Hirschgässlein 11
CH-4051 Basel

Basis of the examination: ✓ VDI 2047, Blatt 2 (01/2015)

Validity period: 5 years 11/2015 – 11/2020

Test report: W-264299-15-Ho



In conclusion it can be stated that the examined evaporation coolers type „HTK“, as specified in the test report W-264299-15-Ho, is in compliance with the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water Hygiene
and Environmental Microbiology

(Dipl.-Ing. (FH) S. Horn)
Department of Water Hygiene
and Environmental Microbiology

issued 30.11.2015, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt-ID: DE125018356
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)